

Installation manual  
**PV SOLAR  
MODULE**

PLEASE READ THIS MANUAL CAREFULLY BEFORE OPERATING  
YOUR SET AND RETAIN IT FOR FUTURE REFERENCE

---

**LG MonoX<sup>®</sup> Plus**

**P-TYPE MODELS**

LGXXS1C(W)-A5

LGXXS2W-A5

**LG NeON<sup>™</sup> 2**

**N-TYPE MODELS**

LGXXN1C(W,K)-A5

LGXXN2C(W,K)-A5

## CONTENTS

1. Safety	3
2. Before & After Installation	5
3. Electrical Installation	7
4. Mechanical Installation	9
5. Product Specifications	11
6. Disclaimer of Liability / Disposal	13
7. Transporting and Storage	13
8. Appendix.	14

## REVISIONS TABLE

Date	Version	Description of change	Remark
2016.09.27	1.0 (1st edition)		
2016.11.30	2.0	Add N-Type Products	
2017.01.10	3.0	Add P-Type Product (302W) Edit to Modules CAD Drawings	

# 1. SAFETY

The instructions related to the safety indicated in the following are for preventing unexpected danger or damage in advance by safely and exactly using the product.

**⚠ DANGER** Non-compliance of the instructions may immediately cause serious injury or death.


**⚠ WARNING** Non-compliance of the instructions may cause death or serious injury to the user.

**⚠ CAUTION** Non-compliance of the instructions may cause injury or property damage to the user.

- ⚠ DANGER**
1. Do not contact with electrically active parts of the panel, such as terminals, regardless of connection of the module. It may result in spark or lethal electric shock.
  2. Please don't use the module with the broken window or the torn back side. There is a danger of electric shock.




- ⚠ WARNING**
1. Please perform works in the dry condition and use only dry tools. Do not handle the wet panels without protection equipment. It may result in safety accident.
  2. Damaged module must be treated with safety protection equipment. It may result in injury.
  3. Do not approach the damaged or broken module unless you are an expert. It may result in serious injury.
  4. No electrical parts like cables are located after installation between laminate and mounting structure.
  5. Do Not reconnect or repair Junction box Cable. It may occur spark or electric shock.
  6. Do not bending junction box's cable. While under stress, it may occur module damage. Cable bending radius should be more than 4 times the cable diameter, at least.



# 1. SAFETY



1. Please use proper equipment, connector, wire and buttness for system configuration of the module. It may result in damage or failure of the product.
2. Do not perform installation in rainy, heavily windy or snowy days. It may result in safety accident.
3. Do not make holes in the frame or glass of the module. It may decrease the strength of the frame or break the glass.
4. Do not touch the glass surface or frame of the solar module after installation of the module. It may result in injury.
5. Do not locate a heavy object onto the module. Do not stand on or step on the module. Do not drop or suddenly lay down the module. It may result in injury.
6. Do not scratch the coating surface of the frame. It may decrease the strength due to corrosion of the frame.
7. Do not concentrate sunlight on the module surface. It may result in damage of the product.
8. Do not apply a shock to the junction box of the module or pull the cable. Do not remove the labels attached to the module. It may result in damage of the product.
9. If the installing structure has a curved surface e.g. arch type as shown in the below picture, do not forcefully modify the module in installation when connecting it with the structure. Please install the module in the place where the structure has been completely set up because deformation of the structure may cause deformation of the product when performing installation by using a crane, etc after assembling the module to the installing structure.



## 2. BEFORE & AFTER INSTALLATION

### Before Installation

Please carefully read this manual before installation.

- Solar module installation should be performed by an authorized installer for the safety and maintenance of the system.
- All installation instructions should be clearly understood before attempting installation.
- Do not twist, pull, or scratch the cable attached to the solar module.
- Do not touch the solar module with bare hands. It may result in a burn or injury.
- Do not drop the solar module and cause an excessive load on solar module.
- Do not disassemble the solar module.
- After installation or repair, check whether solar module operates properly or not.
- In case the currently used solar module or the parts applied to the solar module have been replaced, check whether the changed solar module is properly operated or not. The newly replaced solar module and its parts must be the same solar module(module name) and parts with the current solar module.
- Please contact the local office to confirm the regulations and to obtain permission.
- Do not let anyone approach the solar module who has little knowledge of solar modules or on the measures to take when solar modules are damaged in order to avoid the risk of injury or electrical shock.
- Do not locate the solar module horizontally, as this may cause dirt or white efflorescence (glass deformation)
- Panels produce voltage even when not connected to an electrical circuit or load.
- Panels are intended for outdoors, land based applications only. Panels are not intended for use indoor use or application on moving vehicles of any kind.
- Reflection from external environments such as snow, water or other surfaces can increase the power generated by the panel.
- Industry standard rated specifications are made at conditions of 1,000W/m<sup>2</sup> irradiance and 25°C (77°F) solar cell temperature. Colder temperatures can substantially increase voltage and power.
- Keep the solar module and system away from children when installing.
- Keep the module packed in the carton until the time of installation.
- Make sure flammable gases are not generated near the installation site.
- Do not work alone. Please work as part of a team of two or more people.
- Wear a safety belt if working high above the ground.
- Contact with electrically active parts of the panels, such as terminals, can result in burns, sparks and lethal shock whether the panel is connected or disconnected.
- Even partial shadowing can substantially reduce panel and system output.
- Care must be taken to avoid low tilt angles which may cause dirt to buildup on the glass against the frame edge.
- Dirt build-up on the surface of the panel can cause active solar cells to be shaded and electrical performance to be impaired.
- Always keep the back surface of the panel free from any foreign objects or structural elements which could come into contact with the panel, especially when the panel is under mechanical load.
- For permission to use mounting methods not described in the Mounting Guide please consult LG Solar. Failure to do so will void the warranty and panel certification.

## 2. BEFORE & AFTER INSTALLATION

### After Installation

- Plug the connector in tightly and ensure that the wiring properly works.
- It is advisable to conduct periodic inspection of the panels for damage to front glass, back sheet, frame, junction box, or external electrical connections.
- Check electrical connections for loose connections and corrosion.
- PV panels can operate effectively without ever being washed, although removal of dirt from the front glass can increase output.
- Water, ethanol or a conventional glass cleanser with a micro-fiber cloth can be used for regular washing or rinsing of the front glass to remove dust, dirt or other deposits.
- No aggressive and abrasive cleansers or chemicals such as alkali chemicals including ammonia based solution should ever be used on the treated front glass.
- Always wear rubber gloves for electrical insulation while maintaining, washing or cleaning panels.
- Deposits of foreign material on the frame surface can be cleaned using a wet sponge or cloth and dried in air or by using a clean chamois.
- Perform the wiring work by connecting the connector and wires to the stand away from the roof or ground.

### 3. ELECTRICAL INSTALLATION

#### Caution


- Avoid all electrical hazards when installing, wiring, operating and maintaining a panel.
- Do not use panels of different electrical or physical configurations in the same system.
- Match the polarities of cables and terminals when making the connections; failure to do so may result in damage to the panel.
- When reverse currents can exceed the value marked on the name plate, a properly rated and certified over-current device (fuse or circuit breaker) must be connected in series with each panel or string of panels.
- The rating of the over-current device shall not exceed the maximum series fuse rating marked on the name plate.
- The panel contains factory installed bypass diodes located inside the junction box.
- When installing the system, it is recommended to install the lightning rod to protect the system.
- The junction box should not be opened. Opening the junction box may void the warranty.
- Panels with a suspected electrical problem should be returned to LG Electronics for inspection and possible repair or replacement as per the warranty conditions provided by LG Electronics.

#### Electrical Connections

- Modules may be connected in series and/or parallel to achieve the desired electrical output as long as certain requirements are met.
- Please use only the same type of modules in a combined source circuit.
- Do not disconnect the module under load. Shock hazard can occur near the solar modules connection means.

#### Series Connection

- The solar modules may be wired in series to produce the desired voltage output.
- The current of each module connected in series should be same.
- The maximum number of series connected modules can be determined by basis on max. system voltage, the 125% safety factor, and the module Voc which can be checked in "Product Specifications" in this document.
- Do not exceed 80% of maximum system voltage.
- The maximum solar module configuration can be found in "Product Specifications".




Series connection for more voltage

### 3. ELECTRICAL INSTALLATION

#### Parallel Connection

- The solar modules may be combined in parallel to produce the desired current output.
- When modules are combined in parallel, the total current is equal to the sum of currents from each module.
- The voltage of each module connected in parallel should be same.
- When connecting plural strings of modules in parallel every series string or solar module must be fused prior to combining with other strings. By pass diodes are factory installed in the solar modules.
- Please refer to the applicable regional and local codes for additional fusing requirements and limitations on the maximum number of solar modules in parallel.
- Maximum series fuse rating is refer to “Product Specifications; page 11”
- A multiplying factor is required for increased output of the PV modules. Under normal conditions, a PV module is likely to experience conditions that produce more current and/or voltage than reported at standard test conditions. Accordingly, the values of Isc and Voc marked on this PV module should be multiplied by a factor of 125% when determining component voltage ratings, conductor ampacities, fuse sizes, and size of controls to the PV output.
- Depending on national directives additional safety factors might be applicable for overcurrent protection.




Parallel connection for more current

#### General Wiring

- LG Electronics recommends that all wiring be double insulated with a minimum rating of 90°C (194°F).
- All wiring should use a flexible copper (Cu) conductor.
- The minimum size should be determined by the applicable codes.
- We recommend a size not smaller than 4mm<sup>2</sup>.

#### Earth Grounding

- The solar modules from LG Electronics meet the conditions of safety class II. Therefore grounding is not mandatory. However grounding is recommended. Also equipotential bonding must be realized. The national directives must be respected.
- Specific information on the solar module dimensions and location of grounding holes is provided in ‘Product Specifications.’
- One M4 stainless steel bolt, one nut, one spring washer, two flat washers, one cup washer, one star washer and 12 AWG Cu wires are recommended per solar module.
- There is an earth hole in the center of the module frame. Using this hole, an earth conductor and the solar module frame may be recommended to connected and earthed as the below drawing.
- To prevent electric shock and fire, a protective ground must be done on the frames of solar modules and arrays although the solar modules from LG meet the conditions of safety class II. The national directives must be respected.



## 4. MECHANICAL INSTALLATION

### Module Mounting

- The LG Electronics' (LGE) Limited Warranty for solar modules is contingent upon modules being mounted in accordance with the requirements described in this section.
- The solar modules are in Application Class A and have the Safety Class II. Therefore they can be operated in systems with 120 V DC and higher. General access is not restricted.

### Site Consideration

LGE solar modules should be mounted in a location that meets the following requirements.

### Operating Temperature


- Maximum Operating Temperature: +90°C (194°F)
- Minimum Operating Temperature: -40°C (-40°F)

### Excluded Operating Environments

- The solar modules from LG Electronics can be operated in a location where they could come in contact with salt water or ammonia, if they have been tested successfully for these operating conditions. Please see related certificates. Please get a release from LG Electronics for increased conditions.


### Design Strength

- Snow loads (Front side): 5,400 Pascal
- Wind loads (Rear side): 2,400 Pascal
- Use corrosion resistant material mounting rails and hardware.
- Use appropriate bolted connections as per manufacturer's instructions.
- No electrical parts like cables are located after installation between laminate and mounting structure.



60Cell	① : 200mm ② : 300mm
72Cell	① : 300mm

- This mounting method is by using frame bolt holes.
- The mounting rails must run perpendicularly to the module long side.



## 4. MECHANICAL INSTALLATION


### Mounting Methods

#### General Information

- Select the appropriate orientation to maximize sunlight exposure.
- In order to prevent water from entering the junction box, which could present a safety hazard, module should not be mounted such that the front/top glass faces downward.
- Clearance between the solar module frames and structures such as roofs or ground is required to prevent wiring damage and to allow air to circulate behind the solar module. The recommended standoff height is a minimum of 100mm.
- When installed on a roof, the solar module must be mounted over a fire-resistant roof covering rated for the application. The fire resistance of the solar module from LG Electronics is class C after ANSI/UL790.
- The solar module is only IEC listed for use when its factory frame is fully intact.
- Do not remove or alter the solar module frame.
- Creating additional mounting holes may damage the solar module and reduce the strength of the frame.
- A 6mm gap between module frames should be allowed to avoid tension from thermal expansion.
- The solar module may be mounted using the following methods: (\*Torque: 8~12Nm )
- When installing modules in heavy snow areas, special care should be taken to install the modules in a manner that provides sufficient design strength while meeting local code requirements.

#### Mounting by using frame bolts holes


- Secure the solar module to the structure using the factory mounting holes.
- Four M8 stainless steel bolts, four nuts, four spring washers, and eight flat washers are recommended per solar module.
- The module may be fastened to a support using both the outer and inner bolt holes of the frame.
- Each module should be securely fastened at a minimum 4 points on two opposite sides.
- Specific information on the solar module dimensions and location of mounting holes is provided in 'Product Specifications.'
- Tighten the bolt securely using this combination. Place spring washer between Flat washer and Nut.



\* Mounting Rails Material : Aluminum, Stainless steel, etc.  
 → We recommend more than 40x40mm mounting rails.


#### Mounting by using clip or clamps

- The module may be fastened to a support using clips or clamps on both the long edge and the short edge of the modules.
- Specific information on location of clamping is provided in 'Mechanical Installation Scene' (Refer Appendix.).
- The module frame must overlap more than 15mm.



#### Clamp system requirements

- Clamp width is more than 30mm, depth is more than 10mm. Clamp height compliant with a frame height.
- The clamp should not be touched with the module's glass.
- Use corrosion resistant material clamps and hardware. (If you use a special clamp, it needs to test for compatibility by LGE.)
- Use appropriate bolted connections as per clamp manufacturer's instructions.
- Follow the clamp manufacturer's recommended applied torque to fasten the clamps.



## 5. PRODUCT SPECIFICATIONS

### P-TYPE MODELS

Rated electrical characteristic except power rating within -0/+3 percent are within 5 percent of measured.

Values at Standard Test Condition (STC) : Irradiance 1,000W/m<sup>2</sup>, Cell temp. 25°C, 1.5AM

Module Series	Model Name	Certificates IEC61215 Ed.2, IEC61730, Safety Class II, CE, ISO9001	Electrical Properties									Mechanical Properties				
			Pmax at STC W	Power Tolerance %	Voc at STC V	Isc at STC A	Vmpp at STC V	Imp at STC A	Max. No. of modules in series	Max. Series Fuse Rating A	Max. System Voltage V	Connector	Length mm	Width mm	Height mm	Weight kg
LGXXX1C(W)-A5	LG280S1C(W)-A5	Yes	280	0-3%	37.7	9.87	30.1	9.31	21	20	1,000	MC4/JM601A	1,686	1,016	40	18.0
	LG285S1C(W)-A5	Yes	285	0-3%	38.0	9.92	30.5	9.35	21	20	1,000	MC4/JM601A	1,686	1,016	40	18.0
	LG290S1C(W)-A5	Yes	290	0-3%	38.3	9.97	31.0	9.36	20	20	1,000	MC4/JM601A	1,686	1,016	40	18.0
	LG295S1C(W)-A5	Yes	295	0-3%	38.6	10.02	31.3	9.43	20	20	1,000	MC4/JM601A	1,686	1,016	40	18.0
	LG300S1C(W)-A5	Yes	300	0-3%	38.9	10.07	31.7	9.47	20	20	1,000	MC4/JM601A	1,686	1,016	40	18.0
	LG302S1C(W)-A5	Yes	302	0-3%	39.1	10.10	31.8	9.51	20	20	1,000	MC4/JM601A	1,686	1,016	40	18.0
	LG305S1C(W)-A5	Yes	305	0-3%	39.2	10.12	32.0	9.54	20	20	1,000	MC4/JM601A	1,686	1,016	40	18.0
	LG310S1C(W)-A5	Yes	310	0-3%	39.5	10.17	32.4	9.58	20	20	1,000	MC4/JM601A	1,686	1,016	40	18.0
	LG315S1C(W)-A5	Yes	315	0-3%	39.8	10.22	32.7	9.64	20	20	1,000	MC4/JM601A	1,686	1,016	40	18.0
LGXXX2W-A5	LG320S1C(W)-A5	Yes	320	0-3%	40.1	10.27	33.1	9.68	19	20	1,000	MC4/JM601A	1,686	1,016	40	18.0
	LG335S2W-A5	Yes	335	0-3%	45.8	9.86	36.0	9.31	17	20	1,000	MC4/JM601A	2,024	1,024	40	21.7
	LG340S2W-A5	Yes	340	0-3%	45.9	9.91	36.4	9.35	17	20	1,000	MC4/JM601A	2,024	1,024	40	21.7
	LG345S2W-A5	Yes	345	0-3%	46.1	9.96	36.7	9.41	17	20	1,000	MC4/JM601A	2,024	1,024	40	21.7
	LG350S2W-A5	Yes	350	0-3%	46.3	10.02	37.1	9.44	17	20	1,000	MC4/JM601A	2,024	1,024	40	21.7
	LG355S2W-A5	Yes	355	0-3%	46.4	10.07	37.4	9.50	17	20	1,000	MC4/JM601A	2,024	1,024	40	21.7
	LG360S2W-A5	Yes	360	0-3%	46.6	10.12	37.7	9.56	17	20	1,000	MC4/JM601A	2,024	1,024	40	21.7
	LG365S2W-A5	Yes	365	0-3%	46.7	10.18	38.0	9.61	17	20	1,000	MC4/JM601A	2,024	1,024	40	21.7
	LG370S2W-A5	Yes	370	0-3%	46.9	10.23	38.3	9.67	17	20	1,000	MC4/JM601A	2,024	1,024	40	21.7
LG375S2W-A5	Yes	375	0-3%	47.1	10.29	38.6	9.72	16	20	1,000	MC4/JM601A	2,024	1,024	40	21.7	

Note ) MC4 formal name : PV-KST4 / 6II-UR, PV-KBT4 / 6II-UR

## 5. PRODUCT SPECIFICATIONS

### N-TYPE MODELS

Rated electrical characteristic except power rating within -0/+3 percent are within 5 percent of measured.

Values at Standard Test Condition (STC) : Irradiance 1,000W/m<sup>2</sup>, Cell temp. 25°C, 1.5AM







Module Series	Model Name	Certificates IEC61215 Ed.2, IEC 61730, Safety Class II, CE, ISO9001	Electrical Properties									Mechanical Properties				
			Pmax at STC W	Power Tolerance %	Voc at STC V	Isc at STC A	Vmpp at STC V	Imp at STC A	Max. No. of modules in series	Max. Series Fuse Rating A	Max. System Voltage V	Connector	Length mm	Width mm	Height mm	Weight kg
LGXXXN1C(W)-A5	LG305N1C(W)-A5	Yes	305	0-3%	40.4	10.25	31.7	9.63	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG310N1C(W)-A5	Yes	310	0-3%	40.5	10.29	32.1	9.67	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG315N1C(W)-A5	Yes	315	0-3%	40.6	10.33	32.5	9.70	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG320N1C(W)-A5	Yes	320	0-3%	40.7	10.37	32.9	9.74	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG325N1C(W)-A5	Yes	325	0-3%	40.8	10.41	33.3	9.77	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG330N1C(W)-A5	Yes	330	0-3%	40.9	10.45	33.7	9.80	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG333N1C(W)-A5	Yes	333	0-3%	41.0	10.47	34.0	9.81	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG335N1C(W)-A5	Yes	335	0-3%	41.0	10.49	34.1	9.83	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG340N1C(W)-A5	Yes	340	0-3%	41.1	10.53	34.5	9.86	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG345N1C(W)-A5	Yes	345	0-3%	41.2	10.57	34.9	9.89	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG350N1C(W)-A5	Yes	350	0-3%	41.3	10.61	35.3	9.92	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG355N1C(W)-A5	Yes	355	0-3%	41.4	10.65	35.7	9.95	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
LGXXXN1K-A5	LG300N1K-A5	Yes	300	0-3%	40.4	10.03	31.7	9.47	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG305N1K-A5	Yes	305	0-3%	40.5	10.07	32.1	9.51	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG310N1K-A5	Yes	310	0-3%	40.6	10.11	32.5	9.55	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG315N1K-A5	Yes	315	0-3%	40.7	10.15	32.9	9.58	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG320N1K-A5	Yes	320	0-3%	40.8	10.19	33.3	9.62	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG325N1K-A5	Yes	325	0-3%	40.9	10.23	33.7	9.65	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG330N1K-A5	Yes	330	0-3%	41.0	10.27	34.1	9.69	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG335N1K-A5	Yes	335	0-3%	41.1	10.31	34.5	9.72	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
	LG340N1K-A5	Yes	340	0-3%	41.2	10.35	34.9	9.75	19	20	1,000	MC4/JM601A/05-8	1,686	1,016	40	18.0
LGXXXN2C(W)-A5	LG360N2C(W)-A5	Yes	360	0-3%	48.5	10.19	37.4	9.63	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG365N2C(W)-A5	Yes	365	0-3%	48.6	10.19	37.8	9.66	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG370N2C(W)-A5	Yes	370	0-3%	48.7	10.23	38.2	9.69	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG375N2C(W)-A5	Yes	375	0-3%	48.8	10.27	38.6	9.72	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG380N2C(W)-A5	Yes	380	0-3%	48.9	10.31	39.0	9.75	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG385N2C(W)-A5	Yes	385	0-3%	49.0	10.35	39.4	9.78	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG390N2C(W)-A5	Yes	390	0-3%	49.1	10.39	39.8	9.81	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG395N2C(W)-A5	Yes	395	0-3%	49.2	10.43	40.2	9.83	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG400N2C(W)-A5	Yes	400	0-3%	49.3	10.47	40.6	9.86	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG405N2C(W)-A5	Yes	405	0-3%	49.4	10.51	41.0	9.89	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG410N2C(W)-A5	Yes	410	0-3%	49.5	10.55	41.4	9.91	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG415N2C(W)-A5	Yes	415	0-3%	49.6	10.59	41.8	9.94	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG420N2C(W)-A5	Yes	420	0-3%	49.7	10.63	42.1	9.98	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG425N2C(W)-A5	Yes	425	0-3%	49.8	10.67	42.5	10.01	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
LGXXXN2K-A5	LG360N2K-A5	Yes	360	0-3%	48.6	9.97	37.8	9.53	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG365N2K-A5	Yes	365	0-3%	48.7	10.01	38.2	9.56	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG370N2K-A5	Yes	370	0-3%	48.8	10.05	38.6	9.59	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG375N2K-A5	Yes	375	0-3%	48.9	10.09	39.0	9.62	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG380N2K-A5	Yes	380	0-3%	49.0	10.13	39.4	9.65	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG385N2K-A5	Yes	385	0-3%	49.1	10.17	39.8	9.68	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG390N2K-A5	Yes	390	0-3%	49.2	10.21	40.2	9.71	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG395N2K-A5	Yes	395	0-3%	49.3	10.25	40.6	9.74	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG400N2K-A5	Yes	400	0-3%	49.4	10.29	41.0	9.76	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG405N2K-A5	Yes	405	0-3%	49.5	10.33	41.4	9.79	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG410N2K-A5	Yes	410	0-3%	49.6	10.37	41.8	9.82	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7
	LG415N2K-A5	Yes	415	0-3%	49.7	10.41	42.2	9.84	16	20	1,000	MC4/JM601A/05-8	2,024	1,024	40	21.7

Note) MC4 formal name : PV-KST4 / 6II-UR, PV-KBT4 / 6II-UR



# 8. APPENDIX.

## Mechanical Installation: 60Cell Model

Fig. 1 Bolting Type		Fig. 2 Clamping Type	
			
① : 200mm ② : 300mm	Front: 6,000Pa Rear: 5,400Pa	A: 200mm B: 400mm	Front: 6,000Pa Rear: 5,400Pa
Fig. 3 Clamping Type		Fig. 4 Clamping Type	
			
A: 200mm B: 400mm	Front: 5,400Pa Rear: 5,400Pa	A: 120mm	Front: 1,800Pa Rear: 1,800Pa
		B: 200mm	Front: 2,400Pa Rear: 2,400Pa
Fig. 5 Clamping Type		Fig. 6 Clamping Type	
			
A: 200mm B: 400mm	Front: 6,000Pa Rear: 5,400Pa	A: 120mm	*4point (①) Front: 1,800Pa Rear: 1,800Pa
C: 120mm	Front: 3,200Pa Rear: 1,800Pa	A: 120mm B: 843±100mm	6point (①+②) Front: 6,000Pa Rear: 5,400Pa







\*4 point installation is allowed in the following cases:

1. Slope roof: If module is installed parallel to the rooftop. 2. Flat roof: If installed with an additional stand such as wind shield or deflector.

Note) All mechanical installation method (Fig.1 to Fig.6) in this appendix were not tested by VDE. It is valuated by LG internal test.

## 8. APPENDIX.

### Mechanical Installation: 72Cell Model

Fig. 1 Bolting Type		Fig. 2 Clamping Type		
				
① : 300mm	Front: 5,400Pa Rear: 4,300Pa	A: 250mm B: 400mm	Front: 5,400Pa Rear: 4,300Pa	
Fig. 3 Clamping Type		Fig. 4 Clamping Type		
				
A: 250mm B: 400mm	Front: 4,300Pa Rear: 4,300Pa	A: 120mm B: 250mm	Front: 1,600Pa Rear: 1,600Pa	
Fig. 5 Clamping Type		Fig. 6 Clamping Type		
				
A: 250mm B: 400mm	Front: 5,400Pa Rear: 4,300Pa	A: 120mm	*4point (①)	Front: 1,600Pa Rear: 1,600Pa
C: 120mm	Front: 3,200Pa Rear: 1,600Pa	A: 120mm B: 1,012±100mm	6point (①+②)	Front: 5,400Pa Rear: 4,300Pa


\*4 point installation is allowed in the following cases:

1. Slope roof: If module is installed parallel to the rooftop. 2. Flat roof: If installed with an additional stand such as wind shield or deflector.

Note) All mechanical installation method (Fig.1 to Fig.7) and bolting method in this appendix were not tested by VDE. It is valuated by LG internal test.


## 8. APPENDIX.

### Mechanical Installation: 72Cell Model



Note) When installed Fig.7, follow the NEXTracker's recommended applied torque and materials to fasten the modules.

#### Bolting Method



- Four M8(5/16inch) stainless steel bolts, four nuts, four spring washers, and eight flat washers are recommended per solar module.

Note) All mechanical installation method(Fig.1 to Fig.7) and bolting method in this appendix were not tested by VDE. It is evaluated by LG internal test.



LG Electronics Deutschland GmbH  
EU Solar Business Group  
Alfred-Herrhausen-Allee 3-5  
65760 Eschborn, Deutschland  
E-Mail: solar@lge.de  
www.lg-solar.com/uk

LG Electronics Inc.  
(Global HQ)  
LG Twin Towers, 128,  
Yeoui-daero,  
Yeongdeungpo-gu,  
Seoul 150-721, Korea

This document is subject to change without notice.  
LG, LG logo and Life's Good are trademarks of LG Electronics,  
Inc. worldwide. Trademarks and intellectual properties of LG  
Electronics, Inc. are protected by international copyright laws.

Document : II-A5-IEC-V3-EN-201609